

FLORIDA BUILDING CODE 2006 SUPPLEMENT

CHAPTER 30 ELEVATORS AND CONVEYING SYSTEMS

Section 3001.2 Change to read as follows:

3001.2 Referenced standards. Except as otherwise provided for in this code, the design, construction, installation, alteration, repair and maintenance of elevators and conveying systems and their components shall conform to ASME A17.1, ASME A17.1S, ASME A90.1, ASME B20.1, ALI ALCTV, ASME A17.3 and ASME A18.1.

The Division of Hotels and Restaurants may grant exceptions, variances and waivers to the Elevator Safety Code as authorized by the Elevator Safety Code . (ASME A 17.1, Section 1.2) and Florida Statutes (Chapter 120.)

Section 3002.8 Change to read as follows:

3002.8 Each enclosed elevator lobby and each elevator machine room shall be provided with an approved smoke detector or other automatic fire alarm initiating device where allowed by NFPA 72 located in the lobby ceiling in accordance with NFPA 72. Smoke detectors ~~may be installed in any hoistway, and shall be installed in hoistways which are sprinklered, and shall not be installed in unsprinklered elevator hoistways unless they are installed to activate the hoistway smoke relief equipment.~~ When the smoke detector is activated, all affected elevators shall operate in conformance with NFPA 72, Section ~~3-9-3~~ 6.15.3.

Fire alarm initiating devices are not required for elevator recall at unenclosed lobbies.

Section 3008.1 Change to read as follows:

3008.1 Serial Numbers

[Preceding text unchanged.]

3. The following rules of ASME A17.1, are hereby amended as follows:

a. ~~Reserved.~~ Rule 2.29.1 is to have the following sentence added at the end of this rule: Each car in a multi-car group shall be sequentially identified from left to right, as viewed from the elevator lobby.

[Remaining text unchanged.]